



Compliance Statement

Screened 1200 MHz Enhanced ISO/IEC, EN & ANSI/TIA Communication Cable

CobiNet Identification, Type CobiLan 1500 S/FTP Cat. 7A
1200 MHz Individual Foil and Overall Braid Screened
100 Ω , 4 Twisted Pairs, 22 AWG, Fire Retardant, LSFRHF, Copper Cable

CobiNet Fernmelde- und Datennetzkomponenten GmbH
Robert-Bosch-Strasse 33
68542 Heddesheim

Compliance Statement No. 111600A

This Screened Enhanced ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, IEC Cable Standard 61156-7, the category 6A requirements of ANSI/TIA Generic Cabling Standard 568-C.2, (modified to cover individual foil and overall braid screened cables) and the requirements of 2nd edition CENELEC Cable Standard EN 50288-4-1 and FprEN 50288-9-1:2011. Fire retardancy is verified according to IEC 60332-2-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment 1 and IEC 60754-2. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.

Hoersholm, 3rd November 2011

A handwritten signature in blue ink, appearing to read 'Ole Lambertsen'.

Ole Lambertsen
Test Responsible

Hoersholm, 3rd November 2011

A handwritten signature in blue ink, appearing to read 'Poul Villien'.

Poul Villien
Coordinating Manager